

# APPROVAL FOR CONSTRUCTION

THE PLANS AND SPECIFICATIONS FOR SEWAGE  
OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

Owner:

James Piper  
6 Grove Rd.  
Rye, NH 03870

APPROVAL # 117577

LOT NUMBERS: n/a  
SUBD. APPVL.#: n/a  
SUBD. NAME:

Copy of Plan & Approval sent to:

Joseph May, BI  
Town Office  
Rye, NH 03870

TYPE OF SYSTEM:

4 bdr.

TOWN/CITY LOCATION:

Rye  
Grove Rd.

STREET LOCATION:

By Applicant: PERMIT # 348

Anne W. Bialobrzewski  
247 Landing Rd.  
Hampton, NH 03842

PLEASE POST IN A CONSPICUOUS PLACE  
DURING CONSTRUCTION.

THIS APPROVAL DOES NOT SUPERCEDE  
ANY EQUIVALENT OR MORE STRINGENT  
LOCAL ORDINANCES OR REGULATIONS.  
STATE STANDARDS ARE MINIMAL  
AND MUST BE MET STATEWIDE.

WHITE= Applicant's; YELLOW= Town's; BLUE= NHWS&PCC file; GOLD= Owner's - (No Action Required)

NOTE: ( ) Gravity system ( ) Gravity system to septic tank and effluent pump chamber  
with disposal system to be constructed on a properly prepared base.

Bed bottom to be set: ( X ) no deeper than 30" below the original grade  
( ) no less than " above the original grade  
( ) no lower than the original grade

to maintain ( X ) 4' minimum above (the reported) (any) seasonal high water table.  
( ) ' minimum above (the reported) (any) ledge depth.  
( X ) 6' minimum above (the reported) (any) impermeable soil.

( ) Fill to prepare disposal area should be a medium to coarse sand (0.5 to 1.0 mm).  
( ) This approval only valid for the above owner's domicile/exemption.

CONDITIONS: 1. See note on plans indicating that system is not designed to  
handle garbage disposal waste.

2. Existing well to be abandoned as per plan.

ADVISE YOUR CONTRACTOR  
OF REQUIRED CHANGES IN  
PLANS AS INDICATED ON THIS  
CONDITIONAL APPROVAL.

are approved this date: 12/14/84

James E. Shepard/blw

revised 8/1/80

By:

James Shepard  
N.H. Water Supply & Pollution Control  
Commission Staff (OVER)

## PERC TEST

DATE: 11/8/84

DEPTH OF HOLE: 30"

RATE OF PERC: 2 MIN/IN

DESIGN LOADING: 4 BEDROOMS

AREA REQUIRED: 750 SQ. FT.

PROPOSED SYSTEM: 25x35 FOR  
875 SQ. FT. AREA PROVIDED

## PLAN OF PROPOSED SEPTIC SYSTEM FOR EXISTING HOUSE

LOCUS: 6 GROVE ROAD  
RYE, NH

OWNER: JAMES PIPER  
6 GROVE ROAD  
RYE, NH 03870

APPLICANT: ANNE W. BIALOBRZESKI  
247 LANDING ROAD  
HAMPTON, N.H. 03842  
DESIGNER PERMIT #348

DATE: 11/30/84

APPROVAL:


REVIEWED AND APPROVED  
IN ACCORDANCE WITH THE  
REQUIREMENTS OF THE  
NEW HAMPSHIRE  
WATER SUPPLY & POLLUTION  
CONTROL COMMISSION

Signed

Date

117577

ADVISE YOUR CONTRACTOR  
OF REQUIRED CHANGES IN  
PLANS AS INDICATED ON THIS  
CONDITIONAL APPROVAL



DEC 11 1984  
WATER SUPPLY & POLLUTION  
CONTROL COMMISSION

23